

Date _____ Project _____ Part # _____

Photometry

- 50° glare cutoff with $UGR_{ave} < 18$
- Field-installed optical accessories without the need for tools (Optional uplights and diffusers)

Black Interior RFL		Lumens @ CCT				
CRI	Power	2700K	3000K	3500K	4000K	5000K
80	30W	4022	4257	4446	4603	4603
	45W	5818	6159	6431	6658	6658
90	30W	3313	3507	3662	3791	3791
	45W	4793	5073	5298	5485	5485

Electrical (VL Driver)

- VL: Line Voltage 100-277 VAC, 50-60 Hz
- < 1% flicker
- 6 kV surge protection, PF>0.9/THD<20%

	Amps @ Line Voltage (VAC)					
	100V	110V	120V	220V	240V	277V
30W	0.30A	0.27A	0.25A	0.14A	0.13A	0.11A
45W	0.45A	0.41A	0.38A	0.20A	0.19A	0.16A

Part # Key (Part A + Part B)

- Not all combinations are valid or readily available
- Call for availability of custom features - MOQ may apply
- Optical accessories and controls may be shipped separately and installed to the base lamp model in the field by the user - Inquire at time of order

PART A: TRANSCENDENT

Series		Reflector		Exterior/Interior Color		Mounting/ Cord Length		Mounting Color		Termination		Reflector Accessory (Field Install)	
TU TC	UL cert. CE cert.	CY07	Cylinder 07"	BK2BK2 WH2BK2	Black/Black White/Black	Hxxx Pxxx Sxxx J000	Hook Pendant Stem Surface	000 WH1 BK1 GR1	None White Black Gray	Wire N515 1430 C716 CONN JP01	Bare Wire NEMA 5-15 NEMA 14-30 CEE 7/16 Connector PSE Bare Wire	UGR DRL CNL WBK	UGR Diffuser Drop Lens Conical Lens Wire guard Black

PART B: LAMP [\(Link to spec sheet\)](#)

Series	Lamp Base		Power		CRI	CCT		Driver		Finish	Optics		Control Module (Field Install)		Accessory (Field Install)			
VA6	X39 E40	EX39 E40	30 45	30W 45W	8 9	80 CRI 90 CRI	22 27 30 35 40 50	2200K 2700K 3000K 3500K 4000K 5000K	VL VH	100-277V Hybrid	AN	Anodized	B90	90° Beam	000 OC1 BLE CSM SYN PRI	None (Base Model) Occupancy & Daylight Bluetooth (Avi-On) Casambi Synapse Manual Set Dim	000 015	None (Base Model) 15% Uplight